


Symbol Legend:

- ESB Supply Cable to be routed underground in 125Ø Duct
- Power Ducts - Allow 2 No. 100Ø Ducts
- Data Duct - Allow 1 No. 100Ø Duct
- Light Duct - Allow 1 No. 100Ø Duct
- Incoming Telecom Ducts - Allow 2 No. 100Ø Ducts
- Eir Access Chamber - As per Eir Specification
- Data Access Chamber - 1000mm x 1000mm x 600mm deep
- LV Access Chamber - 1000mm x 1000mm x 600mm deep
- Allowance for future car charging bay - include for base and duct from switchroom
- New Pole Mounted Light Fitting (5 meter Pole)
- New Pole Mounted Light Fitting (8 meter Pole)



Revision	Date	Checked
<b>ISSUED FOR PART 8 PLANNING</b>		04-02-2021 P DS

**Douglas Carroll**  
CONSULTING ENGINEERS

Office 7, 3rd Floor, Station House, Railway Square, Waterford, IE. X91 T38K  
Tel: 051-306670 Web: www.dcoeng.ie E-mail: info@dcoeng.ie  
Douglas Carroll Consulting Engineers Ltd trading as Douglas Carroll Consulting Engineers

Project FIRE STATION, URLINGFORD, CO. KILKENNY CO. KILKENNY	Client KILKENNY COUNTY COUNCIL
Drawing Discipline Electrical Services Installation	Architect CJFA
Drawing Title Site Plan General Services & Proective Services Layout	

Scale Refer to Scalebar	Drawing Size A1	Drawing By HE	Checked By KF	Date 26-06-2020
Drawing Number <b>W1839-MES1000</b>	Revision <b>0</b>	Stage <b>Part 8 Planning</b>		