



MINIMUM MANHOLE DIAMETERS	
DIAMETER OF LARGEST PIPE IN MANHOLE (mm)	INTERNAL DIAMETER OF MANHOLE (mm)
LESS THAN 375	1200
375 TO 450	1350
500 TO 750	1500

General Notes :

1. No part of this document may be re-produced or transmitted in any form or stored in any retrieval system without the written permission of the Contractor, David Kelly Partnership, as copyright holder except as agreed for use on the project for which the document was originally issued.
2. The contractor is responsible for checking all levels and dimensions on site and shall refer all discrepancies to the Engineer.
3. Only drawings issued for CONSTRUCTION shall be used for construction purposes.
4. Work to figured dimensions only. Do not scale print.
5. Check size of drawing sheet against dimension marks at bottom left hand corner of sheet.

NOTE:

ALL WORKS TO BE TO IRISH WATER
SPECIFICATION AND STANDARD DETAILS
AND AGREED IN ADVANCE OF WORKS

Rev :	Note :		
	Date :	Drawn :	Approved :
P1	Note :		
	Date : 18 OCT. '18	Drawn : RO'S	Approved : DO'S



DAVIDKELLY
PARTNERSHIP
CHARTERED ENGINEERS

Nelson House, Emmet Place, 10 Ormonde Street,
Youghal, Co. Cork. Kilkenny.
t. +353 (0)24 92412 t. +353 (0)56 780126
e. info@dkp.ie www.dkp.ie

Project :
PROPOSED HOUSING SCHEME
CASTLECOMER ROAD,
KILKENNY.

Title : DRAINAGE DETAILS

Purpose of Issue :
PLANNING

Scale :	NTS
---------	-----

Issue No. :	P
-------------	---