



LEGEND:

PROPOSED ROAD SPECIFICATION
 60mm OF PMSMA (14) WEARING COURSE ON
 80mm OF ACBC (28) BASECOURSE ON
 150mm SUB-BASE LAYER COMPACTED HARDCORE TO CLAUSE 808 ON
 350mm MINIMUM CLAUSE 6F2 CAPPING LAYER ON
 TENSAR GEOGRID TRIAX 170 OR EQUIVALENT APPROVED PLUS ADDITIONAL
 CAPPING TO MAKE UP LEVELS AS REQUIRED ON TERRAM.

CARPARKING SPECIFICATION
 150mm STAR ROLLED FINISHED INSITU CONCRETE RC 30/37 5% AIR ENTRAINED
 WITH No. 1 SHEET OF A393 MESH ON
 150mm SUB-BASE LAYER COMPACTED HARDCORE TO CLAUSE 808 ON
 350mm MINIMUM CLAUSE 6F2 CAPPING LAYER ON
 TENSAR GEOGRID TRIAX 170 OR EQUIVALENT APPROVED PLUS ADDITIONAL
 CAPPING TO MAKE UP LEVELS AS REQUIRED ON TERRAM.

FOOTPATH SPECIFICATION
 100mm STAR ROLLED FINISHED INSITU CONCRETE RC 30/37 5% AIR ENTRAINED,
 FOOTPATHS & JOINTS TO BE IN ACCORDANCE WITH CL 2.19 & 2.25 OF THE
 SITE DEVELOPMENTS WORKS MANUAL ON
 150mm SUB-BASE LAYER COMPACTED HARDCORE TO CLAUSE 808 ON
 200mm MINIMUM CLAUSE 6F2 CAPPING LAYER ON
 CAPPING TO MAKE UP LEVELS AS REQUIRED ON TERRAM

NOTE: DEPTH OF FOOTPATH TO BE INCREASED TO 200mm WITH 1No. SHEET OF
 A393 MESH AT ALL DRIVEWAY ENTRANCES.

GRASSED AREA SPECIFICATION
 PROPOSED GRASSED AREAS TO LANDSCAPE ARCHITECTS DETAILS.

SHARDED SURFACE SPECIFICATION
 PAVOURS TO ARCHITECTS SPECIFICATION ON
 50mm COMPACTED SAND/CEMENT MIX ON
 150mm SUB-BASE LAYER COMPACTED HARDCORE TO CLAUSE 808 ON
 SECUGRID 40/40 GEOGRID OR EQUIVALENT APPROVED ON
 350mm MINIMUM CLAUSE 6F2 CAPPING LAYER ON
 SECUGRID 40/40 GEOGRID OR EQUIVALENT APPROVED PLUS ADDITIONAL CAPPING
 TO MAKE UP LEVELS AS REQUIRED

FEATURED PAVING SPECIFICATION
 PAVERS TO ARCHITECT SPEC ON
 50MM DEEP COMPACTED PAVING SAND ON
 150mm SUB-BASE LAYER COMPACTED HARDCORE TO CLAUSE 808 ON
 300mm MIN CLAUSE 6F2 CAPPING LAYER ON
 THRACE 40/40 GEOGRID ON
 TERRAM

NOTES:

GENERAL NOTES:

1. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS, SERVICE ENGINEERS DRAWINGS & SPECIFICATIONS.
2. ALL LEVELS ARE STRUCTURAL UNLESS NOTED OTHERWISE.
3. ALL WORKS TO BE CARRIED OUT IN ACCORDANCE WITH THE RELEVANT BUILDING REGULATIONS.
4. DO NOT SCALE - WORK TO FIGURE DIMENSIONS ONLY.



Referenced drawings

Dwg No.	Dwg Title

Issue register

Rev.	Date	Description	Des.	Chkd.	Apprd.
PL1	08.02.19	PLANNING ISSUE	MD	NP	NP
PL2	25.02.19	PLANNING ISSUE	MD	NP	NP

Client: **KILKENNY COUNTY COUNCIL**


Job Description: **CROKERS HILL HOUSING DEVELOPMENT**

Status: **PLANNING ISSUE**

Drawing Title: **PROPOSED BUILD UP LAYOUT**

Project No:	Drawing Ref:	Rev:
18KK003	C-004	PL2
Date:	Scale:	
07.02.19	A1 - 1/500; A3 - 1/1000	
Drawn By:	Checked By:	Approved By:
M.DI DATO	N.PATTERSON	N.PATTERSON

Hayes Higgins Partnership
 Gas House Lane, Kilkenny.
 Gas House Lane, Kilkenny. (044) 7164710 (046) 7723223 info@hayeshiggins.com
 58 Fitzwilliam Square, Dublin 2. (01) 4612321 (01) 4625854 admin@hayeshiggins.com



KEY PLAN
N.T.S. SCALE